

**2019-2020  
Annual Performance Report  
The Town of Maxton's Wastewater System**

**I. General Information**

Facility/System Name: Town of Maxton Wastewater Plant

Responsible Entity: Town of Maxton

Person in Charge/Charge: Dennis Freeman

Applicable Permits: NC0027120 / WQ0002527

Description of Collection System or Treatment Process:

The Town of Maxton's wastewater collection system consists of 11 pump stations located throughout the system. There are 27 miles of gravity sewer lines and 3 miles of force main lines. Our Wastewater Plant consists of two plants. The first plant was built in the early 1960's with one aeration ditch, one clarifier, one chlorine contact chamber and two return sludge pumps with a total capacity of 300,000 gallons per day. The second plant was built in 1980 with one aeration ditch, one clarifier, one chlorine contact chamber and two sludge return pumps with total capacity of 300,000 gallons per day. Both plants combined can treat 600,000 gallons per day, but during normal conditions we only use the new part of the facility. Our average flow during dry periods is 250,000 gallons per day. The facility has one 16,000 gallon aerobic digester and three sand drying beds.

**II. Performance**

Text Summary of System Performance from July 1, 2019 through June 30, 2020

The list by month provides any violations of permit conditions or other environmental regulations. Monthly list includes discussion of any environmental impacts and corrective measures taken to address violations.

| <u>Month</u>   | <u>NPDES VIOLATIONS</u> |
|----------------|-------------------------|
| July 2019      | No Violations           |
| August 2019    | No Violations           |
| September 2019 | No Violations           |
| October 2019   | No Violations           |
| November 2019  | No Violations           |

|               |                            |
|---------------|----------------------------|
| December 2019 | No Violations              |
| January 2020  | No Violations              |
| February 2020 | Over flow limit by .019 MG |
| March 2020    | No Violations              |
| April 2020    | No Violations              |
| May 2020      | No Violations              |
| June 2020     | No Violations              |


### **III. Notification**

The Annual Performance Report is available at the Town Hall and customers were notified of this through our customer confidence report which was mailed June 5, 2020.

### **IV. Certification**

I certify under penalty of law that this is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability,

Responsible Person: Dennis Freeman  
Title: Water & Wastewater Superintendent  
Entity: Town of Maxton (Town Of)  
Phone: (910) 844-5607

  
\_\_\_\_\_  
Dennis Freeman Water/Wastewater Director